

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <b>J</b>		PAGE OF PAGES <b>1   2</b>	
2. AMENDMENT/MODIFICATION NO. <b>0004</b>		3. EFFECTIVE DATE <b>04-Aug-2004</b>		4. REQUISITION/PURCHASE REQ. NO. <b>W16ROE-4070-6647</b>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN:CENAN-CT ROOM 1843 26 FEDERAL PLAZA NEW YORK NY 10278		CODE <b>W912DS</b>		7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. <b>W912DS-04-B-0006</b>			
				<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) <b>12-Jul-2004</b>			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is as follows: (see attached sheets)  Bid Opening date remains 11 August 2004 at 11:00 A.M. in Room 1841.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED <b>04-Aug-2004</b>	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

**AMENDMENT #0004**

The following need to be incorporated into the amendment:

**1. Amend # 3, Item 3, SECTION 02821A (FENCING)**

Para. 3.9 Grounding: Replace 6<sup>th</sup> sentence with the following sentence.

The contractor shall perform ground resistance tests in accordance with IEEE 81 utilizing the fall of potential method, at each end of gate posts opening and any overhead power line crossings and parallel locations, at intervals of 1000 feet.

**2. Following are questions asked by contractors and the responses:**

- a. Survey: the document does not indicate the area to be surveyed. RESPONSE: Per solicitation, survey is required to layout fence route in accordance with plans & specifications.
- b. If bedrock is encountered, how deep should we drill, and what type of material should the contractors use to grout the poles? RESPONSE: See section 02821A, Fence- Paragraphs, 3.3.1 and 2.7.
- c. Can we qualify the lump sum bid? RESPONSE: No.
- d. If the award is not made before the specified date in the documents and the prices of material change, can we request for a change order? RESPONSE: No, if bid is extended.

End of Amendment

(End of Summary of Changes)